

# EC DESIGN EXAMINATION CERTIFICATE

According to the requirements of Directive 97 / 23 / EC  
MODULE B1

Certificate Nr: 12.108.0 Date: 17.12.2013

Manufacturer: ΔΥΝΗ Α.Ε. ΜΗΧΑΝΟΚΑΤΑΣΚΕΥΕΣ  
ΙΩΝΙΑ ΘΕΣΣΑΛΟΝΙΚΗΣ Τ.Κ. 57008 ΘΕΣΣΑΛΟΝΙΚΗ ΕΛΛΑΣ

Applicable Design Code: ELOT EN 303 – 5: 2012

Description: HEATING BOILER FOR SOLID FUELS MANUALLY AND AUTOMATICALLY  
STOKED WITH NOMINAL HEAT OUTPUT OF UP TO 500 KW

Type of Boiler: BC3 50/60  
(Serial Nr. : 1001 / Year: 2013 )

Technical Characteristics: Maximum Allowable Pressure: 3 bar(g)  
Operating Pressure: 2,5 – 3 bar(g)  
Hydrostatic Test Pressure: 4 bar(g)  
Max .Operating Temperature: 95 °C

Nominal heat output: BC3 - 50 : 50 kW, BC3 - 60 : 60 kW.

Boiler Class: 4 for briquettes ( C2 ) & 5 for pellets ( C1 )  
(according to technical file) (Option: The boiler can stoked automatically with solid fuels such as pellets )

Fluid State / Fluid Group: Liquid / 2

Category. / Module: -- / B 1

### Conclusion

This certificate is issued to “ΔΥΝΗ ΜΗΧΑΝΟΚΑΤΑΣΚΕΥΕΣ”, to certify that the undersigned Surveyor has, at their request, examined the technical documentation and identified the components which have been designed in accordance with the relevant provisions of the standards referred to in Article 5 and has and performed the necessary examinations which can be found in the relevant reports.


The certification body ascertains and attests that the design of the boiler described above, meets the provisions of the Annex III – module B1 of Directive 97/23/EC which apply to it.


### Conditions for validity

The applicant must inform the notified body that holds the technical documentation concerning the EC design-examination certificate of all modifications to the approved design; these are subject to additional approval where such changes may affect the conformity of the pressure equipment with the essential requirements of the Directive or the prescribed conditions for use of the equipment. This additional approval must be given in the form of an addition to the original EC design-examination certificate

The manufacturer must keep the technical documentation referred to in Section 3 copies of EC design-examination certificates and their additions for a period of ten years after the last of the pressure equipment has been manufactured. If the standards related to the certified product are amended or new standards are issued, it is necessary to check the applicability of the certificate.



Inspected by  
  
Dimitrios Papadopoulos  
MSc. Dipl. Mechanical Eng. Dr. Welding Eng.  
Level II RT , MT , PT , UT

Approved by:  
  
Lazaros Karanikas  
General Director

## INSPECTION REPORT SUMMARY

**Manufacturer:** ΔΥΝΗ Α.Ε. ΜΗΧΑΝΟΚΑΤΑΣΚΕΥΕΣ  
ΙΩΝΙΑ ΘΕΣΣΑΛΟΝΙΚΗΣ Τ.Κ. 57008  
ΘΕΣΣΑΛΟΝΙΚΗ ΕΛΛΑΣ

**EC Design Examination Certificate:** 12.108.0 of 017.12.2013

**Description:** HEATING BOILER FOR SOLID FUELS MANUALLY STOKED  
WITH NOMINAL HEAT OUTPUT OF UP TO 500 KW

**Type of Boiler:** BC3 50/60

A/A	DESCRIPTION	RESULTS
1	Manufacturer data declaration	Acceptable!
2	Mechanical calculation	Acceptable!
3	Construction dwg.	Acceptable!
4	Material certificates	Acceptable!
5	WPS, PQR , WPQ	Acceptable!
6	Welding map	Acceptable!
7	N.D.T. REPORTS: General inspection report No: Hydrostatic Test Pressure: No:	Acceptable!
8	Instruction and maintenance manual	Acceptable!
9	Manufacturer declaration of conformity CE	Acceptable!
10	Checking of name plate	Acceptable!
11	Hazard and risk analysis	Acceptable!

The boiler described above, after examination of the technical documentation, inspection and checking of testing procedures, is found to be in compliance with the essential requirements referred to in 2.10, 2.11, 3.4, 5 (a) and 5 (d) of Annex I of the relevant Legislation and specification (FEK 987/27.5.99 – PED 97/23 EC).



Inspected by



Dimitrios Papadopoulos  
MSc. Dipl. Mechanical Eng. Dr. Welding Eng.  
Level II RT , MT , PT , UT

